

ADDENDUM TO
CONTRACT DOCUMENTS
AND SPECIFICATIONS

WATER MAIN EXTENSION PART C: HOLLIER ROAD AND KELLI DRIVE
FOR THE CITY OF BREAUX BRIDGE, LOUISIANA
(DSA No. 4849.02)

ADDENDUM NO. 1

November 20, 2018

The following items shall take precedence over referenced to counterparts in the specifications, contract drawings and any other documents in conflict herewith.

Item No. 1 As a **General Note**– The contract time for the project is 100 calendar days.

Item No. 2 Refer to the Specifications and Contract Documents, Section 02715 – Specifications for installations of Water Mains, Measurement and Payment, Fire Hydrants; **As a Note of Clarification:** Payment for hydrants shall include all work and materials necessary to complete the item of work from the main line tee to the hydrant including anchor couplings, bends, gate valve, hydrant, etc. The main line tee will be paid under the respective pay item for fittings.

Item No. 3 Refer to the Specifications and Contract Documents, Section 02715 – Specifications for Installation of Water Mains, Measurement and Payment; **As a Note of Information:** The estimated quantity for fittings is based on the weights of AWWA C110 fittings. Payment will be based on the actual weight installed as per the specifications.

Item No. 4 Refer to the Specifications and Contract Documents, Section 02715 – Specifications for Installation of Water Mains, Measurement and Payment, **As a Note of Clarification:** Pipe installed by jack or bore shall be paid for under the pay item “Install by Jack or Boring” and the corresponding “Furnish and Install ___” Water Main”

Item No. 5 Refer to the Specifications and Contract Documents, Section 02715 – Specifications for Installation of Water Mains, Measurement and Payment, **As a Note of Clarification:** Only pipe specifically identified on the plans or directed in writing by the engineer to be installed by jack or bore or directional boring shall be paid for under the pay item “Install by Jack or Boring” or the “Horizontal Directional Boring” pay items. Pipe installed by directional boring or jack or boring not specifically identified or authorized shall be paid for under the “Furnish & Install ___” Water Main” pay item.

Item No. 6 Refer to the Specifications and Contract Documents, Section 00300 – Bid Form. **REPLACE** this section in the Specifications and Contract Documents with the attached, revised section. Note: the correct, revised bid form will contain a note with the “Bid For” section at the top of the bid form labeled **REVISED ADDENDUM #1**. The section was revised to:

- add the unit price item: Remove and Replace Water Meter Box and Cover and Reconnect Service. Qty: 11.0 each

The purpose of this change is to add the materials and labor necessary to remove existing meters and boxes located along Hollier Road and to replace the existing meters and boxes with new boxes and covers compatible with Advanced Meter System (AMA/AMI) meters to be supplied by the City of Breaux Bridge.

Item No. 7 Refer to the Specifications and Contract Documents, Section 00300 – Bid Bond. **REPLACE** this section in the Specifications and Contract Documents with the attached, revised section. Note: the correct, revised bid form will contain a footer labeled **REVISED ADDENDUM #1**. The section was revised to:

- change the obligee listed in the Bid Bond to the City of Breaux Bridge, Louisiana

Item No. 8 Refer to the Specifications and Contract Documents, Section 02716 – Specifications for Water Meters. **REPLACE** this section in the Specifications and Contract Documents with the attached, revised section. to the Specifications and Contract Documents. Note: the correct section will contain a footer labeled **ADDENDUM #1**. The section was revised to:

- add a description for the pay item “Remove and Replace Water Meter Box and Cover and Reconnect Service”.

Item No. 9 **PRIOR APPROVAL LIST:** The following manufacturers’ equipment may be considered for use on this project (they have received prior approval subject to the following):

The Engineer may allow minor deviations subject to the Engineer’s judgment as to whether such deviations would detract from the quality, reliability or function of the equipment. The equipment manufacturer shall be responsible for any and all redesign required to accommodate their equipment. All drawings and calculations detailing the deviations from the plans and specifications shall be submitted to the Engineer with the shop drawings for approval. Drawings must be in AutoCad 2000 or more recent format and must be stamped by an Engineer licensed in the State of Louisiana. Submit both hard copies and electronic copies for approval.

Prior approval of other manufacturers’ equipment shall in no way relieve the Contractor of responsibility for submitting the specified shop drawings for approval or complying fully with ALL provisions of the specifications and drawings.

If prior approved equipment is used, the contractor shall, at his own expense, make any changes or additions in the structures, piping, electrical, etc. as necessary to accommodate the equipment. If engineering is required due to substitution of prior approved equipment, the contractor shall furnish and pay for all such engineering services. No qualifications or exceptions listed in

prior approval submittals shall in any way alter or serve as substitute provisions relative to this contract.

<u>Section</u>	<u>Description of Items</u>	<u>Approved Mfr.</u>
02715	Tapping Sleeve	Ford SST
02715	Restrained Joint PVC Pipe	North American C900/RJIB Certa-Lok
02715	Fire Hydrant	M&H Model 129
02715	Resilient Wedge Gate Valve	M&H Style 7000

Received by:

Signed: _____

Dated: _____

Company: _____

**FAX THIS SIGNED PAGE TO DOMINGUE, SZABO & ASSOCIATES, INC. AT
337-237-7132; OR RESPOND TO EMAIL ACKNOWLEDGING RECEIPT OF
ADDENDUM**

End of Addendum No. 1



LOUISIANA UNIFORM PUBLIC WORK BID FORM

TO: Mayor & Board of Alderman
City Hall
Breaux Bridge, LA 70517

(Owner to provide name and address of owner)

BID FOR: WATER MAIN EXTENSION – PART C:
HOLLIER ROAD AND KELLI DRIVE
REVISED ADDENDUM #1

(Owner to provide name of project and other identifying information)

The undersigned bidder hereby declares and represents that she/he; a) has carefully examined and understands the Bidding Documents, b) has not received, relied on, or based his bid on any verbal instructions contrary to the Bidding Documents or any addenda, c) has personally inspected and is familiar with the project site, and hereby proposes to provide all labor, materials, tools, appliances and facilities as required to perform, in a workmanlike manner, all work and services for the construction and completion of the referenced project, all in strict accordance with the Bidding Documents prepared by: _____

Domingue, Szabo & Associates, Inc. and dated: October, 2018

(Owner to provide name of entity preparing bidding documents.)

Bidders must acknowledge all addenda. The Bidder acknowledges receipt of the following **ADDENDA:** (Enter the number the Designer has assigned to each of the addenda that the Bidder is acknowledging) _____ .

TOTAL BASE BID: For all work required by the Bidding Documents (including any and all unit prices designated "Base Bid" * but not alternates) the sum of:

_____ Dollars (\$ _____)

ALTERNATES: For any and all work required by the Bidding Documents for Alternates including any and all unit prices designated as alternates in the unit price description.

Alternate No. 1 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:

N/A _____ Dollars (\$ _____)

Alternate No. 2 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:

N/A _____ Dollars (\$ _____)

Alternate No. 3 *(Owner to provide description of alternate and state whether add or deduct)* for the lump sum of:

N/A _____ Dollars (\$ _____)

NAME OF BIDDER: _____

ADDRESS OF BIDDER: _____

LOUISIANA CONTRACTOR'S LICENSE NUMBER: _____

NAME OF AUTHORIZED SIGNATORY OF BIDDER: _____

TITLE OF AUTHORIZED SIGNATORY OF BIDDER: _____

SIGNATURE OF AUTHORIZED SIGNATORY OF BIDDER **: _____

DATE: _____

THE FOLLOWING ITEMS ARE TO BE INCLUDED WITH THE SUBMISSION OF THIS LOUISIANA UNIFORM PUBLIC WORK BID FORM:

* The Unit Price Form shall be used if the contract includes unit prices. Otherwise it is not required and need not be included with the form. The number of unit prices that may be included is not limited and additional sheets may be included if needed.

** **A CORPORATE RESOLUTION OR WRITTEN EVIDENCE** of the authority of the person signing the bid for the public work as prescribed by LA R.S. 38:2212(B)(5).

BID SECURITY in the form of a bid bond, certified check or cashier's check as prescribed by LA R.S. 38:2218(A) attached to and made a part of this bid.

LOUISIANA UNIFORM PUBLIC WORK BID FORM UNIT PRICE FORM

TO: Mayor & Board of Alderman
City Hall
Breaux Bridge, LA 70517

(Owner to provide name and address of owner)

(Owner to provide name of project and other identifying information)

BID FOR: WATER MAIN EXTENSION -PART C: HOLLIER
ROAD AND KELLI DRIVE
REVISED ADDENDUM #1

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install 8" PVC Water Line	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
REF. NO. 1			6860 Linear Feet		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install 8" Restrained Joint PVC Water Line			
REF. NO. 2			730 Linear Feet		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install 8" Restrained Joint PVC Water Line			
REF. NO. 3			60 Linear Feet		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install 8" DR 18 Fusible Water Line by Directional Bore Crossing LA Hwy 347			
REF. NO. 4			150 Linear Feet		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install by Jack or Bore 4" Restrained Joint PVC Water Line			
REF. NO. 5			200 Linear Feet		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install by Jack or Bore 3/4" HDPE Water Service Line			
REF. NO. 6			380 Linear Feet		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Install by Jack or Bore 8" Water Main			
REF. NO. 7			2 Each		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install 8" x 8" Tapping Sleeve and Valve			
REF. NO. 8			3 Each		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install 8" x 4" Tapping Sleeve and Valve			
REF. NO. 9			8 Each		
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Furnish & Install 8" Gate Valve with Box			

LOUISIANA UNIFORM PUBLIC WORK BID FORM UNIT PRICE FORM

TO: Mayor & Board of Alderman
City Hall
Breaux Bridge, LA 70517

BID FOR: WATER MAIN EXTENSION - PART C: HOLLIER
ROAD AND KELLI DRIVE
REVISED ADDENDUM #1

(Owner to provide name and address of owner)

(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.
 Base Bid or Alt.# Furnish & Install 4" Gate Valve with Box

REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
10	3	Each		

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Furnish & Install Fire Hydrant, Type I			
11	5	Each	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Furnish & Install Fire Hydrant, Type II			
12	11	Each	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Furnish & Install 6" Vertical Hydrant Extension			
13	20	Linear Feet	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Furnish & Install Restrained Joint Ductile Iron Fittings			
14	2.30	Tons	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Furnish & Install Meter Box, Cover, Valve, and Service			
15	4	Each	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Remove and Replace Water Meter Box and Cover and Reconnect Service			
16	11	Each	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Top Soil			
17	100	Cubic Yards	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# <u> </u> Hydro-seeding			
18	6.00	Acres	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)

LOUISIANA UNIFORM PUBLIC WORK BID FORM UNIT PRICE FORM

TO: Mayor & Board of Aldermen
City Hall
Breaux Bridge, LA 70517

BID FOR: WATER MAIN EXTENSION - PART C: HOLLIER
ROAD AND KELLI DRIVE
REVISED ADDENDUM #1

(Owner to provide name and address of owner)

(Owner to provide name of project and other identifying information)

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Limestone for Embedment and Backfill			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
19	150	Cubic Yards			
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Limestone for Maintenance and Drives			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
20	50	Tons			
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Fill-Crete			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
21	20	Cubic Yards			
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Special Backfill			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
22	50	Cubic Yards			
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Mobilization			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
23	1	Lump Sum			
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Removal & Disposal of Structures, Obstructions, and Debris			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
24	1	Lump Sum			
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Temporary Signs & Barricades, Traffic Control			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
25	1	Lump Sum			
DESCRIPTION:	<input checked="" type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.#	Preservation & Restoration of Private Property and Rights of Way			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)	
26	1	Lump Sum			

BID BOND

Date: _____

KNOW ALL MEN BY THESE PRESENTS:

That _____ of _____, as Principal, and _____, as Surety, are held and firmly bound unto the City of Breaux Bridge, Louisiana (Obligee), in the full and just sum of five (5%) percent of the total amount of this proposal, including all alternates, lawful money of the United States, for payment of which sum, well and truly be made, we bind ourselves, our heirs, executors, administrators, successors and assigns, jointly and severally firmly by these presents.

Surety represents that it is listed on the current U. S. Department of the Treasury Financial Management Service list of approved bonding companies as approved for an amount equal to or greater than the amount for which it obligates itself in this instrument or that it is a Louisiana domiciled insurance company with at least an A - rating in the latest printing of the A. M. Best's Key Rating Guide. If surety qualifies by virtue of its Best's listing, the Bond amount may not exceed ten percent of policyholders' surplus as shown in the latest A. M. Best's Key Rating Guide.

Surety further represents that it is licensed to do business in the State of Louisiana and that this Bond is signed by surety's agent or attorney-in-fact. This Bid Bond is accompanied by appropriate power of attorney.

THE CONDITION OF THIS OBLIGATION IS SUCH that, whereas said Principal is herewith submitting its proposal to the Obligee on a Contract for:

NOW, THEREFORE, if the said Contract be awarded to the Principal and the Principal shall, within such time as may be specified, enter into the Contract in writing and give a good and sufficient bond to secure the performance of the terms and conditions of the Contract with surety acceptable to the Obligee, then this obligation shall be void; otherwise this obligation shall become due and payable.

PRINCIPAL (BIDDER)

SURETY

BY: _____
AUTHORIZED OFFICER-OWNER-PARTNER

BY: _____
AGENT OR ATTORNEY-IN-FACT(SEAL)

SECTION 02716 – SPECIFICATIONS FOR WATER METERS

PART 1 - GENERAL

RELATED DOCUMENTS:

Drawings and general provisions of the Contract, including General and Special Conditions and Division 1 Specification Sections, apply to this Section.

Comply with requirements of applicable Division 2 sections required in connection with piping.

Description of Work:

Extent of the meter work shall be as shown on the plans and specified herein. The work includes remove existing water meters (Owner will provide and install new AMA/AMI meters), remove and replace existing meter boxes (new boxes will be furnish with covers compatible with the Advanced Meter System (AMA/AMI), all tubing, corporation stops, taps, and other work as necessary to complete the work as specified.

QUALITY ASSURANCE:

Installer: A firm with at least two (2) years of successful installation experience on piping projects similar to this project.

Code Compliance: Comply with applicable portions of the Louisiana State Sanitary Code and the National Standard Plumbing Code. Where in conflict, the more stringent shall govern.

SUBMITTALS:

Product Data: Submit manufacturer's product data and installation instructions for each product specified.

PART 2 - PRODUCTS

General: Provide ells, tees, reducing tees, wyes, couplings, restraint devices and other required piping accessories of the same type and class of material as the conduit, or of material having equal or superior physical and chemical properties as acceptable to the Engineer. Pipe shall be furnished in the estimated quantities and with the type of joint listed in the bid form.

METER COVERS:

Meter Covers shall be constructed of non-ferrous material. Covers shall be impact and UV resistant and specifically manufactured for use with AMR meters. Existing covers shall be returned by delivering to the Owner with the meters.

METER BOXES:

Meter boxes shall be Ford Meter Box YLHC241-233 w/check valve. Existing boxes shall be returned by delivering to the Owner with the meters.

PART 3 - EXECUTION

Removal of Existing Meters:

All meters are to be carefully removed and logged per instructions below. All meters will be delivered to the City of Breaux Bridge's Water Plant for storage. Any meters damaged during removal and/or delivery to the water plant shall be replaced in kind by the contractor at no additional cost to the Owner. The Contractor shall submit the specified documentation to the Owner with the delivery of the meters. Documentation shall include: location of meter, date of removal, size and type of meter, manufacturer, serial number, and FINAL READING. Failure to record the final reading may result in the Contractor being responsible for payment of the final water bill.

New Meter Installation:

General: All new meters shall be installed by the City of Breaux Bridge upon notification from the Contractor that the new service and valve box have been installed and the Contractor is ready to change service over from the old meter to the new one. Adequate notice must be given by the Contractor to the City to properly prepare for the new meter installations. Contractor shall coordinate with City officials before work begins to determine how much lead time the City will require to install the new meters.

Interruption of Service: Water service to customers shall be maintained without interruption as much as possible. Interruption of service shall be allowed only at times agreed to by the Owner.

MEASUREMENT & PAYMENT:

General: There shall be NO direct pay for any work or incidentals required to complete the various pay items listed on the bid form that are not specifically identified. All work required to complete the identified pay items shall be included in the various items of work.

Furnish and Install Meter Box, Cover, Valve, and Service: Payment for furnishing and installing meter box, cover, valve, service, and incidentals shall be based on the actual number of meter boxes and service lines/connections installed at the price bid per each for "Furnish and Install Meter Box, Cover, Valve, and Service". The unit price shall include all materials, labor, equipment, and incidentals to complete the item, including but not limited to, meter box and cover, customer cutoff valve, service line, and equipment, installation of new meter box, cover and valve, installation of new service line, service line connection, corporation stop, and required equipment and hardware, specified documentation, disinfection, other materials, labor, equipment, tools, supplies, and incidentals necessary to complete all items of work in accordance with the drawings and these specifications.

Remove and Replace Water Meter Box and Cover and Furnish and Install new Service:
Payment for removal and replacement of water meter boxes and covers, and installation of new service line and incidentals shall be based on the actual number of services reestablished at the price bid per each for "Remove and Replace Water Meter Box and Cover and Reconnect Service". The unit price shall include all materials, labor, equipment and incidentals to complete the item, including but not limited to, removal of existing meter, meter box and cover, service line, and equipment, delivery of meters to the Owner, installation of new meter box and cover, installation of new service line, corporation stop, and required equipment and hardware, specified documentation, disinfection, other materials, labor, equipment, tools, supplies, and incidentals necessary to complete all items of work in accordance with the drawings and these specifications.

END OF SECTION 02716