

**ADDENDUM TO  
CONTRACT DOCUMENTS  
AND SPECIFICATIONS**

**Squirrel Run Pump Station Rehabilitation Project  
For the City of New Iberia, LA**

---

**ADDENDUM NO. 2**

**JUNE 12, 2019**

---

The following items shall take precedence over referenced to counterparts in the specifications, contract drawings and any other documents in conflict herewith.

**Item No. 1** REFER to the Plans, Sheet E1 – Electrical, Note 2 in lower right corner. The conduit provided shall be Schedule 40 PE.

Received by:

Signed: \_\_\_\_\_

Dated: \_\_\_\_\_

Company: \_\_\_\_\_

**FAX THIS SIGNED PAGE TO DOMINGUE, SZABO & ASSOCIATES, INC. AT  
337-237-7132; OR RESPOND TO EMAIL ACKNOWLEDGING RECEIPT OF ADDENDUM**

End of Addendum No. 2

