



November 3, 2021

102 Asma Boulevard
Suite 305
Lafayette, LA 70508

(337)232-5182
FAX (337)237-7132

www.dsaengineering.com

TO ALL HOLDERS OF PLANS
AND SPECIFICATIONS:

RE: Water Well No 7
City of Breaux Bridge, LA
(DSA No. 4879.02)

ATTENTION:

Attached is ADDENDUM NO. 1 for the subject project. Please include it in your set of specifications and consider it when making your bid.

Sincerely,

DOMINGUE, SZABO & ASSOCIATES, INC.

Chris Richard, PE

CKR/
Enclosure(s)

**ADDENDUM TO
CONTRACT DOCUMENTS
AND SPECIFICATIONS**

**WATER WELL NO. 7
CITY OF BREAUX BRIDGE, LA
(DSA No. 4879.02)**

ADDENDUM NO. 1

November 3, 2021

The following items shall take precedence over referenced to counterparts in the specifications, contract drawings and any other documents in conflict herewith.

Item No. 1 REFER to the Specifications and Contract Documents, **Section 00300 – Bid Bond.** There were two Bid Bond Forms inadvertently included in the specifications. Delete the Bid Bond that refers to a 10% Bid Bond Amount. Bid Bond shall be in the amount of 5% of the bid.

Item No. 2 As a note of **Clarification:** Refer to Section 10500 – Water Wells – Drilling; Well shall be under-reamed of sufficient size to allow 7” annular opening completely around well screen.

Item No. 3 **PRIOR APPROVAL LIST:** The following manufacturers’ equipment may be considered for use on this project (they have received prior approval subject to the following):

The Engineer may allow minor deviations subject to the Engineer’s judgment as to whether such deviations would detract from the quality, reliability or function of the equipment. The equipment manufacturer shall be responsible for any and all redesign required to accommodate their equipment. All drawings and calculations detailing the deviations from the plans and specifications shall be submitted to the Engineer with the shop drawings for approval. Drawings must be in AutoCad 2019 or more recent format and must be stamped by an Engineer licensed in the State of Louisiana. Submit both hard copies and electronic copies for approval.

Prior approval of other manufacturers’ equipment shall in no way relieve the Contractor of responsibility for submitting the specified shop drawings for approval or complying fully with ALL provisions of the specifications and drawings.

If prior approved equipment is used, the contractor shall, at his own expense, make any changes or additions in the structures, piping, electrical, etc. as necessary to accommodate the equipment. If engineering is required due to substitution of prior approved equipment, the contractor shall furnish and pay for all such engineering services. No qualifications or exceptions listed in prior approval submittals shall in any way alter or serve as substitute provisions relative to this contract.

<u>Section</u>	<u>Description of Items</u>	<u>Approved Mfr.</u>
11300	Well Pump	National Pump

RESPOND TO EMAIL ACKNOWLEDGING RECEIPT OF ADDENDUM

End of Addendum No. 1

