



& ASSOCIATES, INCORPORATED
PROFESSIONAL ENGINEERS & LAND SURVEYORS

102 Asma Boulevard
Suite 305
Lafayette, LA 70508

(337)232-5182

www.dsaengineering.com

December 28, 2023

TO ALL HOLDERS OF PLANS
AND SPECIFICATIONS:

RE: FILTER REHABILITATION
AT THE
BREAUX BRIDGE WATER TREATMENT PLANT
(DSA No. 4963.02)

ATTENTION:

Attached is ADDENDUM NO. 1 for the subject project. Please include it in your set of specifications and consider it when making your bid.

Sincerely,

DOMINGUE, SZABO & ASSOCIATES, INC.

Chris Richard, PE

CKR/
Enclosure(s)

**ADDENDUM TO
CONTRACT DOCUMENTS
AND SPECIFICATIONS**

**FILTER REHABILITATION
AT THE
BREAUX BRIDGE WATER TREATMENT PLANT
(DSA No. 4963.02)**

ADDENDUM NO. 1

December 28, 2023

The following items shall take precedence over referenced to counterparts in the specifications, contract drawings and any other documents in conflict herewith.

Item No. 1 As a note of CLARIFICATION, the total gravel depth for Filters 1 & 2 shall be 16” and the gravel depth for filters 3 & 4 shall be 12” as per the drawings.

Please acknowledge all addendums individually on the bid form

End of Addendum No. 1

