

**ADDENDUM TO
CONTRACT DOCUMENTS
AND SPECIFICATIONS**

**Water Production Improvements
For the City of Youngsville, LA**

ADDENDUM NO. 1

NOVEMBER 6, 2019

The following items shall take precedence over referenced to counterparts in the specifications, contract drawings and any other documents in conflict herewith.

Item No. 1 Refer to the Contract Drawings, Sheets 3, 4, 5, and 8. The contractor shall coordinate with the electrical subcontractor, the equipment manufacturers, and material suppliers to provide the required size of generator foundation/slab and electrical rack and slab necessary for the installations. The dimensions shown on the drawings are minimum requirements. Contractor must include in his bid any additional cost associated with changes necessary to meet all requirements of the contract documents, equipment manufacturers, material manufacturers, etc.

Item No. 3 **PRIOR APPROVAL LIST:** The following manufacturers' equipment may be considered for use on this project (they have received prior approval subject to the following):

The Engineer may allow minor deviations subject to the Engineer's judgment as to whether such deviations would detract from the quality, reliability or function of the equipment. The equipment manufacturer shall be responsible for any and all redesign required to accommodate their equipment. All drawings and calculations detailing the deviations from the plans and specifications shall be submitted to the Engineer with the shop drawings for approval. Drawings must be in AutoCad 2010 or more recent format and must be stamped by an Engineer licensed in the State of Louisiana. Submit both hard copies and electronic copies for approval.

Prior approval of other manufacturers' equipment shall in no way relieve the Contractor of responsibility for submitting the specified shop drawings for approval or complying fully with all provisions of the specifications and drawings.

If prior approved equipment is used, the contractor shall, at his own expense, make any changes or additions in the structures, piping, electrical, etc. as necessary to accommodate the equipment. If engineering is required due to substitution of prior approved equipment, the contractor shall furnish and pay for all such engineering services. No qualifications or exceptions listed in prior approval submittals shall in any way alter or serve as substitute provisions relative to this contract.

Note: Although prior approval allows the manufacturer to bid the project in accordance with the documents, many of the features/items required by the specifications were listed as optional equipment by the manufacturer (e.g. stainless steel guides, two moisture probes, non-sparking assembly, etc.). It is the Contractor's responsibility to ensure that the products used to determine the bid are in FULL compliance with the specifications, including the costs for the options required to fully meet the specifications.

<u>Section</u>	<u>Description of Items</u>	<u>Approved Mfr.</u>
16231	Generator System	Cummins, Kohler

Received by:

Signed: _____

Dated: _____

Company: _____

FAX THIS SIGNED PAGE TO DOMINGUE, SZABO & ASSOCIATES, INC. AT 337-237-7132; OR RESPOND TO EMAIL ACKNOWLEDGING RECEIPT OF ADDENDUM

End of Addendum No. 1



UNOFFICIAL COPY